

Certificate Number: 8376

**1 DETAILS OF THE CLIENT**

 Client: Dove Lodge  
 Address: 49 Beach Road, Littlehampton, West Sussex, BN17 5JE

**2 DETAILS OF THE INSTALLATION ADDRESS**

 Installation Address: Dove Lodge, 49 Beach Road, Littlehampton, West Sussex, BN17 5JG

**3 EXTENT AND LIMITATIONS OF THE INSTALLATION**

 Extent of the installation and limitations of the inspection and testing:  
 100% of lighting tested to 180 minutes.


**4 EMERGENCY LIGHTING TESTS**

No.	Lamp Normal State	LED Visible	Lamp Emergency State	Battery Time In Minutes	Comments
1	Pass	Pass	Pass	180	N/A
2	Pass	Pass	Pass	180	N/A
3	Pass	Pass	Pass	180	N/A
4	Pass	Pass	Pass	180	N/A
5	Pass	Pass	Pass	180	N/A
6	Pass	Pass	Pass	180	N/A
7	Pass	Pass	Pass	180	N/A
8	Pass	Pass	Pass	180	N/A
9	Pass	Pass	Pass	180	N/A
10	Pass	Pass	Pass	180	N/A
11	Pass	Pass	Pass	180	N/A
12	Pass	Pass	Pass	180	N/A
13	Pass	Pass	Pass	180	N/A
14	Pass	Pass	Pass	180	N/A

**5 ADDITIONAL COMMENTS**

 N/A

**6 DETAILS OF THE CONTRACTOR**

 Trading Title: Barkers Electrical  
 Address: 12 Churchill Parade  
 Rustington  
 West Sussex  
 Postcode: BN16 3DJ  
 Registration Number (if applicable): Napit 33681  
 Telephone Number: 01903 924055  
 For the Testing and Inspection of the emergency lights:  
 Name: Paul Shimell Position: Qualified Supervisor Signature:  Date: 29/07/2024

