

# REPORT OF PERIODIC THOROUGH EXAMINATION OF HOIST OR LIFT

as required by the Lifting Operation and Lifting Equipment Regulations 1998;  
or the Lifting Operations and Lifting Equipment Regulations (Northern Ireland) 1999;  
or the Safety, Health and Welfare at Work (General Application) Regulations 2007 S.I. No. 299.

Policy: X4A0143782

Plant Code: L27AHH

Previous Report: 170523-002-0024EMO

Site: 00001

Schedule: L0001

Date Issued: 02 Jun 2023

Report Number: 020623-001-0025EMO

L0L54

Employer (or owner) of premises	DOVE LODGE COMMUNITY RESOURCE CENTRE
Address	49 Beach Road, Littlehampton, West Sussex, BN17 5JG
1. (a) Type of hoist or lift and identification number and description	Passenger/Goods Lift                      Hydraulic  Oakland Elevators Serial No.:- 8013 Unknown
(b) Date of construction or reconstruction (if ascertainable)	Unknown
2. (a) Is this the first thorough examination following installation of the equipment at the above site/location?	No
(b) Were examinations in accordance with an examination scheme?	No
3. Maintenance Are the following parts of the hoist or lift properly maintained and in good working order? If not, state what defects have been found or tests required to confirm continued safe use.	
(a) Enclosure of hoistway or liftway.	Yes
(b) Landing gates and cage gate(s).	Yes
(c) Interlocks on the landing gates and cage gate(s).	Yes
(d) Other gate fastenings.	Yes
(e) Cage or platform and fittings, cage guides, buffers, interior of hoistway or liftway.	Yes
(f) Over-running devices.	Yes
(g) Suspension ropes or chains, and their attachments.	Direct acting ram.
(h) Safety gear, i.e. arrangements for preventing fall of platform or cage.	SAFed Supplementary Test 4.12.2 (Hydraulic rupture/restrictor valve) completed and dated 20/02/19. Test certificate seen.
(j) Brakes.	Not applicable.
(k) Worm or spur gearing.	Not applicable.
(l) Other electrical equipment.	Yes
(m) Other parts.	Yes
4. What parts (if any) were inaccessible?	Enclosed electrical, mechanical and structural components
5. Repairs, renewals, tests or alterations required to enable the hoist or lift to continue to be operated with safety (if none enter "None") :-	
(a) defects found which give rise to imminent danger and require attention immediately.	None
(b) defects found which could, in time, give rise to danger and require attention or tests required within the specified time period.	None
6. Maximum safe working load subject to repairs, renewals or alterations (if any) specified at 5.	630 kg/8 Persons
7. Other observations	Last service 12/05/23

This is to certify that on the date of examination the hoist or lift was thoroughly examined and unless, otherwise indicated above, was safe to operate, and if the first examination following installation, was installed correctly.

Date of Examination: 31 May 2023

Date of Last Examination: 25 Jul 2022

Inspecting Engineer: Mr K Halom

Date of Next Examination: 30 Nov 2023

Signature:



Qualification: Engineer Surveyor

**HSB Engineering Insurance Services Limited**

Registered in England and Wales: 03010292,  
Chancery Place, 50 Brown Street, Manchester M2 2JT  
Registered as a branch in Ireland: 906105  
28 Windsor Place, Lower Pembroke Street, Dublin 2

Telephone: 0845 345 5510  
HSB Engineering Insurance Services Limited  
is accredited by the United Kingdom  
Accreditation Service



0010

SAFed  
SAFETY ASSESSMENT  
FEDERATION